CITY OF NEWARK
Delaware

CONTRACT NO. 15-05
WATER TANK MIXER INSTALLATION

ADDENDUM NO. 2
April 1, 2015

1.1   PROJECT INFORMATION

   A.   Project Name: WATER TANK MIXER INSTALLATION.

   B.   Owner: CITY OF NEWARK.

   C.   Owner Project Number: CONTRACT 15-05.

   D.   Engineer: Pennoni Associates.

   E.   Date of Addendum: April 1, 2015.

1.2   NOTICE TO BIDDERS

   A.   This Addendum is issued to all registered plan holders
        pursuant to the Conditions of the Contract. This Addendum
        serves to clarify, revise, and supersede information in the
        Project Manual, Drawings, and previously issued Addenda.
        Portions of the Addendum affecting the Contract Documents
        will be incorporated into the Contract by enumeration of the
        Addendum in the Owner/Contractor Agreement.

   B.   The Bidder shall acknowledge receipt of this Addendum with
        their submitted proposal.

   C.   The date for receipt of bids is unchanged by this Addendum.

1.3   QUESTIONS

   A.   Questions posed since Addendum 1 with responses.
        Q: Where will the city want the mixer control panel at
            Louviers Tank?
        A: *Inside the base area of the tank near the electrical
            panel.*

Q: Diameters of Tanks?
A: *Please consult specification and contract documents. Tank information is provided on the site plan for each tank.*

Q: Do mixers have to be located in the center of the tank? Or is there a preferred location?
A: *Mixers shall be installed per manufacturer's recommendations per Section 46 41 46 "Water Tank Mixers"*

Q: Can you confirm hatches on the tops of all tanks?
A: *West Main-Yes; Louviers-Yes; Arbour Park-Yes; Windy Hills-Yes; Paper Mill-Yes;* Dallam-Yes; New London-Yes

Q: Will the city coordinate the temporary power shutdown with the owners of any antennas on the tank?
A: *Yes, The City will coordinate with the contractor to temporary suspend any electrical on the site.*

Q: Confirm power at Dallam Road?
A: *The City of Newark Electric will make power available. The Contractor should coordinate scheduling with the City.*

END OF ADDENDUM 2